



Rescinding Drinking Water Advisory

December 21, 2018

Sun Dale Recreation Ltd. c/o RM of McKillop
P.O. Box 220
Bulyea, SK
S0G 0L0

Dear Waterworks Owner/Operator:

RE: Rescinding - Precautionary Drinking Water Advisory

The Water Security Agency, in consultation with the Saskatchewan Health Authority-Regina Office, is advising that the **"Precautionary Drinking Water Advisory" (PDWA)** issued by the Water Security Agency for Sun Dale's potable water system has been rescinded, as of Friday, December 21, 2018.

The rescinding of the PDWA was based upon information provided by your community, which included:

- Repairs are completed and the system is back to normal pressure
- Chlorine and turbidity are within regulated limits
- Bacteriological sampling was negative.

Your community may return to normal monitoring requirements as identified in your permits monitoring schedule.

In closing, I would like to acknowledge that the Water Security Agency appreciates the efforts and cooperation demonstrated by staff at your water treatment plant, as well as officials of the Development of Sun Dale in addressing the advisory.

Should you have any questions or concerns, please call me at (306) 694-3939.

A handwritten signature in blue ink that reads "Lauren Daly".

Lauren Daly, BSc. Hons

Environmental Project Officer
Environmental Services Section - South
Environmental and Municipal Management Services Division